

AGENDA
CONSTRUCTION BOARD OF APPEALS
CITY COUNCIL CHAMBERS

February 8, 2016

3:00 P.M.

1. Call to Order
2. Roll Call
3. Approval of Minutes
4. Public Hearings

Appeal #V16-0002

Applicant: Field's Fire Protection, Inc.
Location: 1375 28th St. S.W.

Request: The purpose is to hear all interested parties regarding the request for an appeal of the 2012 Michigan Mechanical Code 705.2.4 Extra-heavy-duty which requires an independent exhaust systems for Type I hoods for extra-heavy-duty cooking appliances. Applicant requests the City approve the installation of a gas radiant charbroiler with smoker boxes based on Section 14.3.4 of the 2014 Edition of NFPA 96, which allows an exception of the separate exhaust if 11 conditional requirements are met. Applicant is prepared to argue construction meets the 11 conditional requirements, and as such the separate exhaust is not required. P.P. No. 41-17-11-376-018

Tabled	_____	Closed	_____
Granted	_____ X _____	Denied	_____
Motion by	_____ Kirby _____		
Seconded by	_____ Wood _____		
Yeas	_____ 5 _____	Nays	_____ 0 _____

Res. #1024

5. New Business: